
## **TELCO-Style Cable Runway**

Similar in construction to our UL Classified Cable Runway (11275 Series). The side stringers are 1 1/2" x 3/8" x .065" (38 mm x 9.53 mm x 1.65 mm) and the cross members are 1/2" x 1" x .065" (12.7 mm x 30 mm x 1.65 mm) welded at 9" (230 mm) intervals. With the runway supported every 5' (1.5 m), maximum load with minimal deflection is 132 lb/ft (196 kg/m).

- The overall length is 9' 8-1/2"116.5" (2959 mm) or 4' 5-1/2"/53.5"
   (1359 mm) to comply with TELCO-Style standards
- Individually boxed to prevent scratching and damage
- Installation Best Practices includes Runway Elevation Kit



## **ORDERING INFORMATION**

Part Number	Width (Dim. A) in (mm)	Length (Dim. B) in (mm)			
11252-X06	6 (150)	9′ 8-1/2 (2959)			
11252-X09	9 (230)	9′ 8-1/2 (2959)			
11252-X10	10 (250)	9′ 8-1/2 (2959)			
11252-X12	12 (300)	9′ 8-1/2 (2959)			
11252-X13	12 (300)	4′ 5-1/2 (1359)			
11252-X15	15 (380)	9′ 8-1/2 (2959)			
11252-X18	18 (460)	9′ 8-1/2 (2959)			
11252-X20	20 (510)	9′ 8-1/2 (2959)			

X=color: 1=Gray, 2=Computer Beige, 7=Black, E=Glacier White.

United States
Agoura Hills, CA
800-834-4969
Canada
Taranta Ontaria

Toronto, Ontario, Cana +905-850-7770 **Europe** Buckinghamshire, UK F441628524834 Middle East & Africa Dubai, UAE +971-4-2602125

Doha, Qatar +974-4-267422 Latin America +52-55-5203-7525 Toll Free within Mexico 800-201-7592 chatsworth.com.co Asia Pacific +86 21 6880-0266 chatsworth.com.cn



## **Cable Runway Load-Span Table**

Maximum load with minimal deflection is 132 lb/ft when the runway is supported every 5'.

## Load-Span Table, CPI Cable Runway

Safety Factor	Span (ft)	4	5	6	7	8	9
1.5	Maximum Load (lb/ft)	206	132	92	67	52	41
	Defection (in)	0.41	0.64	0.92	1.25	1.62	2.03
2.0	Maximum Load (lb/ft)	154	99	69	50	39	31
	Defection (in)	0.31	0.48	0.68	0.93	1.21	1.531
	K factor	0.002	0.005	0.010	0.019	0.032	0.050

CPI recommends supporting cable runway runs every 5 feet.

To calculate deflection for loads lighter than maximum loads listed in table, .multiply load for which deflection is desired by K factor listed in table for cable runway support span utilized.

Example: To calculate maximum deflection using a safety factor of 1.5 for a length of cable runway supported every 5' and loaded with 80 pounds per foot:

Defection = (80)(0.005) = 0.40"

NOTE: CPI 10250, 11252, 11275 and 14300 cable runway systems are listed under UL E138966 and tested to the requirements in the Standard for Safety for Metal Cable Tray Systems, NEMA VE 1-2009 and ANSI/NFPA 70.

